

CLEAR LAKE RANCH PUD (PWS # 5240033) SOURCE WATER ASSESSMENT FINAL REPORT

April 16, 2003



State of Idaho Department of Environmental Quality

Disclaimer: This publication has been developed as part of an informational service for the source water assessments of public water systems in Idaho and is based on the data available at the time and the professional judgement of the staff. Although reasonable efforts have been made to present accurate information, no guarantees, including expressed or implied warranties of any kind, are made with respect to this publication by the State of Idaho or any of its agencies, employees, or agents, who also assume no legal responsibility for the accuracy of presentations, comments, or other information in this publication. The assessment is subject to modification if new data is produced.

Executive Summary

Under the Federal Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency (EPA) to assess every source of public drinking water for its relative sensitivity to contaminants regulated by the Act. The Idaho Department of Environmental Quality (DEQ) is completing the assessments for all Idaho public drinking water systems. The assessment for your particular drinking water source is based on a land use inventory within a 1,000-foot radius of the drinking water source, sensitivity factors associated with the source, and characteristics associated with either your aquifer or watershed in which you live.

This report, *Source Water Assessment for Clear Lake Ranch PUD: Public Water System (PWS) #5240033* describes the public drinking water system, the associated potential contaminant sources located within a 1,000-foot boundary around the drinking water source, and the susceptibility that may be associated with any associated potential contaminants. This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this system. **The results should not be used as an absolute measure of risk and is not intended to undermine the confidence in your water system.**

The Clear Lake Ranch PUD drinking water system consists of one spring. The system serves approximately 60 people through 14 connections.

Final susceptibility scores are derived from System Construction scores and Potential Contaminant/Land Use scores. Potential Contaminants/Land Uses are divided into four categories, inorganic contaminants (IOCs, e.g. nitrates, arsenic), volatile organic contaminants (VOCs, e.g. petroleum products), synthetic organic contaminants (SOCs, e.g. pesticides), and microbial contaminants (e.g. bacteria). As different springs can be subject to various contamination settings, separate scores are given for each type of contaminant.

In terms of overall susceptibility, the system rated moderate susceptibility for IOCs, VOCs, SOCs, and microbial contaminants. System construction rated high, due to unknown information, and land use scores rated moderate for IOCs, low for VOCs, and moderate for SOCs and microbial contaminants.

No VOCs, SOCs, or microbials have ever been detected in tested water. Water tests have detected nitrates in concentrations less than 1.2 parts per million (ppm), significantly less than the EPA's maximum contaminant level (MCL) of 10 ppm. Water tests have also detected trace and safe amounts of the IOCs arsenic, barium, chromium, fluoride, nickel, and sodium. The spring exists within a county of high nitrogen fertilizer and agricultural chemical usage.

Based on the initial computer generated contaminant source inventory conducted by the DEQ, there are seven potential contaminant sources located within the 1,000-foot boundary. This information has been summarized and included in Table 1. A copy of the susceptibility analysis worksheet for your system along with a map showing any potential contaminant sources is included with this summary.

Table 1. Clear Lake Ranch PUD, Potential Contaminant Inventory

SITE #	Source Description ¹	Source of Information	Potential Contaminants ²
1	NPDES Site – aquaculture discharge	Database Search	IOC, SOC, Microbial
2	NPDES Site – aquaculture discharge	Database Search	IOC, SOC, Microbial
3	NPDES Site – aquaculture discharge	Database Search	IOC, SOC, Microbial
4	NPDES Site – aquaculture discharge	Database Search	IOC, SOC, Microbial
5	NPDES Site – aquaculture discharge	Database Search	IOC, SOC, Microbial
6	NPDES Site – aquaculture discharge	Database Search	IOC, SOC, Microbial
	Road	GIS Map	IOC, VOC, SOC, Microbials

¹NPDES = National Pollutant Discharge Elimination System

²IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

Susceptibility Analysis

The water system's susceptibility to contamination was ranked as high, moderate, or low risk according to the following considerations: Physical integrity of the spring, land use characteristics, and potentially significant contaminant sources. The susceptibility rankings are specific to a particular potential contaminant or category of contaminants. Therefore, a high susceptibility rating relative to one potential contaminant does not mean that the water system is at the same risk for all other potential contaminants. The relative ranking that is derived for each drinking water source is a qualitative, screening-level step that, in many cases, uses generalized assumptions and best professional judgement. The following summaries describe the rationale for the susceptibility ranking.

Spring Construction

Spring construction scores are determined by evaluating whether the spring has been constructed according to Idaho Code (IDAPA 58.01.08.04) and if the spring's water is exposed to any potential contaminants from the time it exits the bedrock to when it enters the distribution system. If the spring's intake structure, infiltration gallery, and housing are located and constructed in such a manner as to be permanent and protect it from all potential contaminants, is contained within a fenced area of at least 100 feet in diameter, and is protected from all surface water by diversions, berms, etc., then Idaho Code is being met and the score will be lower. If the spring's water comes in contact with the open atmosphere before it enters the distribution system, it receives a higher score. Likewise, if the spring's water is piped directly from the bedrock to the distribution system or is collected in a protected spring box without any contact to potential surface-related contaminants, the score is lower.

The spring rated high for construction, mostly due to missing information. No sanitary survey was available for this water system, so any rating derived from information on it, resulted in an automatically higher rating. If a sanitary survey had been available, the rating might have been lower.

Potential Contaminant Source and Land Use

The spring rated moderate for IOC's (e.g., arsenic, nitrate), low for VOC's (e.g., petroleum products), and moderate for SOC's (e.g., pesticides) and microbial contaminants (e.g., bacteria). The small number of potential contaminant sites and amount of agricultural land contributed to the scores.

Final Susceptibility Rating

An IOC detection above a drinking water limit, any detection of a VOC or SOC, or a detection of total coliform bacteria or fecal coliform bacteria at the drinking water source will automatically give a high susceptibility rating to that source, despite the land use of the area, because a pathway for contamination already exists. Additionally, having potential contaminant sources within 100 feet of the spring will give an automatic high susceptibility rating.

If an automatic high rating is not received, overall system ratings are derived by system construction scores and potential contaminant sources in the 0- to 3-year time-of-travel zone (Zone 1B).

In this case, the Clear Lake Ranch PUD water system rated moderate for IOC's, VOC's, SOC's, and microbial contaminants.

Options for Drinking Water Protection

This assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what ranking a source receives, protection is always important. Whether the source is currently located in a "pristine" area or an area with numerous industrial and/or agricultural land uses, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

For Clear Lake Ranch PUD, drinking water protection activities should focus on ensuring compliance with the 2000 sanitary survey and minimizing spills or releases associated with the NPDES sites and the roads which pass through the designated source water area. In addition, a more favorable rating could be achieved if the system was confirmed to be compliant with the Idaho regulations for Public Drinking Water Systems. Partnerships with state and local agencies and industry groups should be established and are critical to success. You may want to establish a dialog with the relevant state and local agencies related to the NPDES sites and the road.

Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term. A strong public education program should be a primary focus of any drinking water protection plan. There are multiple resources available to help communities implement protection programs, including the Drinking Water Academy of the EPA. For areas where transportation corridors transect the delineation, the Idaho Department of Transportation should be included in protection activities. Drinking water protection activities for agriculture should be coordinated with the Idaho State Department of Agriculture, the Soil Conservation Commission, the local Soil Conservation District, and the Natural Resources Conservation Service.

Assistance

Public water suppliers and others may call the following DEQ offices with questions about this assessment and to request assistance with developing and implementing a local protection plan. In addition, draft protection plans may be submitted to the DEQ office for preliminary review and comments.


Twin Falls Regional DEQ Office (208) 736-2190

State DEQ Office (208) 373-0502

Website: <http://www.deq.state.id.us>

Water suppliers serving fewer than 10,000 persons may contact Melinda Harper, mlharper@idahoruralwater.com, Idaho Rural Water Association, at 208-343-7001 for assistance with drinking water protection (formerly wellhead protection) strategies.

Clear Lake Ranch P U D: Well #1
PWS Number: 5240033



Legend

- Wellhead
- + Enhanced Inventory
- Toxic Release Inventory
- CERCLIS Site
- RICIS Site
- Business Mailing List
- ★ Dairy
- LUST Site
- UST Site
 - ▲ Closed
 - ▲ Open
- NPDES Site
- ⌵ Mine
- AST
- Recharge Point
- SARA Title III Site (EPCRA)
- Injection Well
- Group I Site
- Cyanide Site
- Boise VOCs
- Landfill
- Wastewater Land App. Site
- Transient Delineation

Restoration of Liability:
 Neither the State of Idaho nor the Idaho Department of Environment and Quality, nor any of their employees make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness or usefulness of any information or data provided. Metadata is provided for all data sets, and no data should be used without first reading and understanding its limitations. The data could include technical inaccuracies or typographical errors. The Department of Environment and Quality may update, modify, or remove the data used at any time, without notice.



POTENTIAL CONTAMINANT INVENTORY LIST OF ACRONYMS AND DEFINITIONS

AST (Aboveground Storage Tanks) – Sites with aboveground storage tanks.

Business Mailing List – This list contains potential contaminant sites identified through a yellow pages database search of standard industry codes (SIC).

CERCLIS – This includes sites considered for listing under the **Comprehensive Environmental Response Compensation and Liability Act (CERCLA)**. CERCLA, more commonly known as ASuperfund, is designed to clean up hazardous waste sites that are on the national priority list (NPL).

Cyanide Site – DEQ permitted and known historical sites/facilities using cyanide.

Dairy – Sites included in the primary contaminant source inventory represent those facilities regulated by Idaho State Department of Agriculture (ISDA) and may range from a few head to several thousand head of milking cows.

Deep Injection Well – Injection wells regulated under the Idaho Department of Water Resources generally for the disposal of stormwater runoff or agricultural field drainage.

Enhanced Inventory – Enhanced inventory locations are potential contaminant source sites added by the water system. These can include new sites not captured during the primary contaminant inventory, or corrected locations for sites not properly located during the primary contaminant inventory. Enhanced inventory sites can also include miscellaneous sites added by the Idaho Department of Environmental Quality (IDEQ) during the primary contaminant inventory.

Floodplain – This is a coverage of the 100-year floodplains.

Group 1 Sites – These are sites that show elevated levels of contaminants and are not within the priority one areas.

Inorganic Priority Area – Priority one areas where greater than 25% of the wells/springs show constituents higher than primary standards or other health standards.

Landfill – Areas of open and closed municipal and non-municipal landfills.

LUST (Leaking Underground Storage Tank) – Potential contaminant source sites associated with leaking underground storage tanks as regulated under RCRA.

Mines and Quarries – Mines and quarries permitted through the Idaho Department of Lands.)

Nitrate Priority Area – Area where greater than 25% of wells/springs show nitrate values above 5mg/l.

NPDES (National Pollutant Discharge Elimination System) – Sites with NPDES permits. The Clean Water Act requires that any discharge of a pollutant to waters of the United States from a point source must be authorized by an NPDES permit.

Organic Priority Areas – These are any areas where greater than 25 % of wells/springs show levels greater than 1% of the primary standard or other health standards.

Recharge Point – This includes active, proposed, and possible recharge sites on the Snake River Plain.

RICRIS – Site regulated under **Resource Conservation Recovery Act (RCRA)**. RCRA is commonly associated with the cradle to grave management approach for generation, storage, and disposal of hazardous wastes.

SARA Tier II (Superfund Amendments and Reauthorization Act Tier II Facilities) – These sites store certain types and amounts of hazardous materials and must be identified under the Community Right to Know Act.

Toxic Release Inventory (TRI) – The toxic release inventory list was developed as part of the Emergency Planning and Community Right to Know (Community Right to Know) Act passed in 1986. The Community Right to Know Act requires the reporting of any release of a chemical found on the TRI list.

UST (Underground Storage Tank) – Potential contaminant source sites associated with underground storage tanks regulated as regulated under RCRA.

Wastewater Land Applications Sites – These are areas where the land application of municipal or industrial wastewater is permitted by IDEQ.

Wellheads – These are drinking water well locations regulated under the Safe Drinking Water Act. They are not treated as potential contaminant sources.

NOTE: Many of the potential contaminant sources were located using a geocoding program where mailing addresses are used to locate a facility. Field verification of potential contaminant sources is an important element of an enhanced inventory.

Where possible, a list of potential contaminant sites unable to be located with geocoding will be provided to water systems to determine if the potential contaminant sources are located within the source water assessment area.

References Cited

Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, 1997. “*Recommended Standards for Water Works.*”

Idaho Department of Environmental Quality, 1997. *Design Standards for Public Drinking Water Systems*. IDAPA 58.01.08.550.01.

Idaho Department of Water Resources, 1993. *Administrative Rules of the Idaho Water Resource Board: Well Construction Standards Rules*. IDAPA 37.03.09.

The final scores for the susceptibility analysis were determined using the following formulas:

- 1) VOC/SOC/IOC/Microbial Final Score = System Construction + (Potential Contaminant/Land Use x 0.818)

Final Susceptibility Scoring:

0 - 7 Low Susceptibility

8 - 14 Moderate Susceptibility

≥ 15 High Susceptibility

1. System Construction			SCORE			
Intake structure and area constructed to meet Idaho Code		NO	1			
Does the water enter the distribution system without contacting the atmosphere		NO	2			
YES = lower score, NO = higher score						
Total System Construction Score			3			
2. Potential Contaminant / Land Use - ZONE 1A			IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A		DRYLAND AGRICULTURE	1	1	1	1
Farm chemical use high		YES	2	0	2	
IOC, VOC, SOC, or Microbial sources in Zone 1A		NO	NO	NO	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A			3	1	3	1
Potential Contaminant / Land Use - ZONE 1B						
Contaminant sources present (Number of Sources)		YES	7	1	7	7
(Score = # Sources X 2) 8 Points Maximum			8	2	8	8
Sources of Class II or III leacheable contaminants or		YES	1	1	1	
4 Points Maximum			1	1	1	
Zone 1B contains or intercepts a Group 1 Area		NO	0	0	0	0
Land use Zone 1B Greater Than 50% Non-Irrigated Agricultural			2	2	2	2
Total Potential Contaminant Source / Land Use Score - Zone 1B			11	5	11	10
Cumulative Potential Contaminant / Land Use Score			14	6	14	11
3. Final Susceptibility Source Score			14	8	14	12
4. Final Well Ranking			Moderate	Moderate	Moderate	Moderate